

Validation of IBR equivalent plant level PSCAD model using Synchrophasor measurements

Srinivas Chitturi*, Minnakuri Venkateswara Rao, Pradeep Kumar Sanodiya,
Vishal Puppala, Omkar Kumbhar, Kunal Roy, S S Raghuwanshi, Pushpa. S




Grid Controller of India Limited

formerly Power System Operation Corporation Ltd. (POSOCO)

Contents

- **Indian Grid**
- **Additional Transmission system for Renewables**
- **Western Regional Grid of India**
- **Renewables Integration Process**
- **Verification of models**
- **Validation of PSCAD simulation Model**
- **Conclusion**

Indian Grid.. One of the World's Largest



- 1 National synchronous grid**
- 3 Electricity consumption**
- 4 Wind generation**
- 5 Renewable Energy generation**
- 6 Hydro generation**
- 9 Pumped storage capacity**

Source: IEA Key World Energy Statistics 2020 & IHA 2020 Hydro Status Report (2018 data, 2019 provisional data).



Green Energy Corridor

Transmission system planned for major RE potential zones in

- Northern Region
- Western Region
- Southern Region


Planned transmission schemes considering

- Energy storage
- Hydro electric plants
- Green hydrogen production

Transmission System for Integration of over 500 GW RE Capacity ~ 2030

Planned additional transmission systems of

- 8120 ckm of HVDC corridors
- 25,960 ckm of 765 kV AC lines
- 15,758 ckm of 400 kV AC lines
- 1052 ckm of 220 kV cables



Western Regional (WR) Grid of India

#Map not to scale

World's largest RE park

Western



Khavda
in Rann of Kutch



- 50% of All India 765 kV lines are in WR

- WR is Vital highway for energy transmission to other Regional grids of India

World's largest RE park in Gujarat state, India

30 GW of Clean energy ~ peak demand and RE generation




Area of 726 square kilometers

- Installed capacity: 141 GW
Comparable to Size of Singapore


#Map not to scale
*Locations and placement of RE resources & transmission lines are only for illustration
-<https://ornatesolar.com/news>

Grid Integration Process-RE Generator




CTU: Central Transmission Utility
RLDC: Regional Load Despatch Centre

Verification of Model Data-Pre Commissioning



Verification of Model Data-Post Commissioning

Installation of any additional equipment & changes in controller settings



Updated implemented controller and protection settings






Compliance checks through Reports & Simulations

- Within 03 months of commissioning, detailed and equivalent models to be submitted
- Updated implemented controller and protection settings (both IBR and Power Plant Controller) shall also be submitted
- Changes in the plant due to installation of additional equipment, changes in controller settings- updated models to be submitted


Detailed equivalent models




Compliance Checks on Models



Reactive Capability assessment



Voltage Ride Through Requirement (Low/High)



Frequency Response




Active and Reactive Power - Set Point Control



Design Requirement - Weather, Temperature Extremes etc.



Ramping Capability




Power Quality Requirements


Compliance Check-Fault Ride Through (FRT)

Low Voltage Ride Through (LVRT): Shall remain connected to the grid when voltage dips, supply reactive power, active power may reduce for specified time period

High Voltage Ride Through (HVRT): Shall remain connected to the grid when voltage swells for specified time & support to grid.



RE Plant Voltage, Active and Reactive Power



During fault ride through priority is

1. Reactive power
2. Active power
3. Revival just after fault to pre fault conditions in specified time

Validation of IBR Plant

- 324.4 MW of Wind Plant
- Interconnected with grid via single 220 kV transmission line



- Event at nearby sub-station (L-G fault)
- Voltage ~ 0.86 PU at Wind Plant
- Validation of submitted PSCAD simulation model

IBR: Inverter Based Resource

#Map not to scale

*Locations and placement of RE resources & transmission lines are only for illustration

Validation of PSCAD Simulation Model






Submitted Equivalent PSCAD Model


Event at nearby sub-station

- Voltage: 0.86 PU at 220 kV Station-B
- 220 kV station-B represented as grid with three phase voltage source
- Input to voltage source-PMU data at station-B.
- Initial conditions: P_SET-270 MW, Plant operated in constant Q-mode (76 MVAR absorption) & capacitor bank kept ON

Simulation Results




PMU Data for IBR Performance



Oscillations Analysis



FRT Performance



Model Validation

Observations

- Lack of Inverter level data
- Multiple RE plants sharing the same evacuating line
- RE power from wind farms and solar farms is evacuated through same evacuating lines
- Lack of high-resolution data-Reporting rate: 40ms

Conclusions

Submitted model represents the actual performance of the plant with slight variations

1

Conducting plant-level testing is not feasible. Instead, validation of plant performance using PMU data or event log data during events is preferable.


2

Validating actual performance supports the tuning of parameters to improve plant performance

3

Difference in actual and simulation responses are due to reactive power support from the plant and individual IBR to terminal voltage vary

4



Thank You



srinivasch@grid-india.in



ग्रिड-इंडिया
GRID-INDIA