

DOE Transmission Reliability R&D Program

Eastern Interconnection Situational Awareness Monitoring System (ESAMS) Demonstration Project

April 12, 2022

Joe Eto Lawrence Berkeley National Laboratory

Neeraj Nayak, Simon Mo, Ken Martin, Song Xue, Horacio Silva-Saravia, Jay Chen Electric Power Group
Jim Follum, Nicholas Betzhold, Shuchismita Biswas, Tianzhixi Yin Pacific Northwest National Laboratory

David Hislop, Chris Callaghan, Hamed Golestani PJM



Electric Power Group



Motivation – January 11, 2019

- Oscillations can affect the behavior of the entire interconnection
- Yet, while operators have *excellent visibility within their footprints....*
.... improving visibility outside their footprints is always desirable



“RCs should improve communication with neighboring RCs in the event of widespread oscillation disturbances on the BPS”

“RCs should consider jointly developing interconnection-wide oscillation detection and source location applications using interconnection-wide PMU and SCADA data.”



Electric Power

Pacific Northwest
NATIONAL LABORATORY

BERKELEY LAB

Project Objectives

Demonstrate an interconnection-wide, high-level, synchrophasor-based monitoring system for the Eastern Interconnection


- ***Provide situational awareness for grid events that can be seen across the Eastern Interconnection – e.g., forced oscillations***
- ***Enhance communications among Reliability Coordinators by providing real-time notifications on the RC footprint that contains the source of a forced oscillation***
- ***Establish a baseline of routine and unusual system behaviors that can only be seen using multiple synchrophasors integrated across the Interconnection***



Electric Power Group



System Architecture for the Prototype System




¹EInet – Eastern Interconnection Data Sharing Network

²RTDMS – Real-Time Dynamics Monitoring System

PMU Signals Currently Streaming into ESAMS

(note: locations approximate)

- ISONE
- MISO
- NYISO
- PJM
- SOCO
- SPP
- TVA



Electric Power Group



ESAMS Applications – Daily Summary Report

Summary (Eastern Standard Time, 24-Hour Format)

Focus of today's
Presentation


Event Type	Event Time (EST)	Additional Information
Interconnection Oscillatory Behavior & Phenomenon		
Forced Oscillation Detection & Source Location	09:16-10:04 <i>Time for event with highest energy</i>	1 forced oscillation event(s) detected Key info for event with highest energy: • Signal: [REDACTED] • Type: Real Power • Frequency: 1.175 Hz • Value: 8.042 MW
Dominant Natural Oscillation Baseline		Daily Report on Natural Oscillations
Ringdown Detection	18:59-18:59 <i>Time for event with the earliest event time</i>	1 ringdown event detected List of angle pair(s) for event with the earliest time: [REDACTED] [REDACTED]
Wide Area Phase Angles		
Rapid Step Changes	05:09 <i>Time for event with the most angle pairs participating</i>	3 events with rapid step changes detected Key info for event with the most angle pairs participating: • Number of Angle Pairs participating: 3 • Most sensitive angle pair during the event: [REDACTED]
Very Large Angles Compared to Recent Observations	00:00-00:01 <i>Time for event with the longest time under stress</i>	2 events with large angles detected Angle Pair with the longest event time: • Angle Pair: [REDACTED]
Atypical Combinations of Rapid Step Changes and Large Angles	00:03 <i>Time for event with the most angle pairs participating</i>	5 Atypical Combinations detected List of angle pair(s) contributed most to the event with the most angle pairs participating: [REDACTED]
PMU Data Quality		
Daily Report on PMU Data Quality		

On December 8, 2021, ESAMS detected a forced oscillation that lasted 36 minutes

ESAMS identified SOCO/FRCC as the likely source


Following additional internal investigation, SOCO reported peak-to-peak was 85 MW

The oscillation was observable across the Eastern Interconnect: 17 MW peak-to-peak at ISNE/NYIS interface




Time (EST): 20:11: - 20:47: Frequency: 0.17 Hz Oscillation Type: Inter-area Oscillations

Rank	Oscillation Detected at	Peak to Peak Amplitude	Oscillation Band RMS Energy
1	[REDACTED]	24.6 MW	8.7 MW
2	[REDACTED]	18.5 MW	6.5 MW
3	[REDACTED]	16.8 MW	5.9 MW
4	[REDACTED]	12.6 MW	4.4 MW
5	[REDACTED]	12.1 MW	4.3 MW



ESAMS assigns a confidence score to the information used to support identification of the RC footprint that is the source of a forced oscillation

Energy Flow Diagram:




Confidence Level Scoring:

FO Source Identification	Region	Confidence Level	Criteria
REGION WITH HIGHEST POSITIVE NET ENERGY FLOW	SOCO/FRCC	Low (1)	High:>2 Medium:2 Low:< 2
Supporting Information	Finding	Confidence Scoring Elements	Scoring Algorithm
DOES THIS REGION ALSO HAVE IMPORTS?	Yes	0	No = + Yes = 0
OTHER REGIONS WITH POSITIVE NET ENERGY FLOW?	3	-	None = + 1 = 0 2 or more = -
ROBUSTNESS OF FINDING	86%	0	<80% = + >80% And ≤90% = 0 >90% = -
SOURCE REGION'S DATA QUALITY/AVAILABILITY	71.4%	+	>90% = + >80% And ≤90% = 0 <80% = -
OVERALL MEASURE OF DATA QUALITY/AVAILABILITY	40%	+	


Forced Oscillation Shape

NE-S mode shape



30 mins data window, Nov 2021, source:[1]

FO shape (December 8, 2021)



Data window: 20:15-20:45 ET, Dec 8, 2021

The forced oscillation shape on Dec 8 conforms to the NE-S mode shape

[1] J. Follum, "Continuous tracking of two oscillatory modes in the Eastern Interconnection", presented at SMWG Meeting, Nov 2021. PNNL-SA-168514



Electric Power Group



Forced Oscillations Detected by ESAMS

(June 2021 – January 2022)

Range of the
two previously
identified
major
oscillatory
modes for the
Eastern
Interconnection



Oscillation Frequencies (Hz)	Count of Forced Oscillation Events	Largest Amplitude
0.13	1	6 MW
0.18	5	25 MW
0.2	2	8 MW
0.24	1	7 MW
0.31	1	6 MW
0.34	7	14 MW
0.36	3	12 MW
0.45	1	10 MW
0.57	1	9 MW
0.66	1	7 MW
0.72	26	11 MW
0.83	12	10 MW
1.17	1	8 MW
1.43	4	3.4 MW
1.72	1	4.2 MW
	Total = 67	


Real-time Notifications were Enabled in January 2022

First real-time notification sent at ~10:30 EDT on March 1, 2022 following detection of a forced oscillation with peak-to-peak amplitude greater than 10 MW

Forced Oscillation Detection & Source Location


Forced Oscillation observed for 02/28/2022

Forced Oscillation event was detected by signal [REDACTED] 03/01/2022 10:30 ET - 03/01/2022 10:39 ET, RC Region with Highest net oscillation energy export: MISO Confidence Level: **Low**
Doesn't appear to be localized only to MISO



Time (EST): 10:30 - 10:39; Frequency: 0.64 Hz; Oscillation Type: Inter-area Oscillations

Rank	Oscillation Detected at	Peak to Peak Amplitude	Oscillation Band RMS Energy
1	[REDACTED]	17 MW	9 MW
2	[REDACTED]	12 MW	7 MW
3	[REDACTED]	11 MW	6 MW
4	[REDACTED]	5 MW	3 MW
5	[REDACTED]	3 MW	6 MW



VIRTUALPMU.AUTAGAVILLE_BIL

ESAMS Industry Partners

PJM – *DEMONSTRATION HOST*– Christopher Callaghan, Hamed Golestani, David Hislop (formerly, Shaun Murphy, Subbarao Eedupuganti, Eric Hsia, and Ryan Nice)

ISO-NE – Frankie Zhang, Slava Maslennikov, Xiaochuan Luo

MISO – Keith Mitchell

NYISO – Emily Fernandez, Shubhrajit Bhattacharjee

Southern Co – Clifton Black, Shih-Min Hsu, James Viikinsalo, Chris Wakefield, Mark Newman, Michael Breuhl, John Pope

SPP – Cody Parker, William Holden, Jennifer Sorrell, Daniel Baker

TVA – Tim Fritch, Gary Kobet, Phillip Crittenden, Jonathan Sides



Electric Power Group



Summary of feedback provided by ESAMS Industry Partners

- ***Real-time notification of forced oscillation RC footprint location was successfully demonstrated***
- ***The RCIS may be an appropriate vehicle for distributing real-time forced oscillation notifications***
- ***ESAMS is a needed extension and complement to (not duplication of) our in-house synchrophasor analysis capabilities***
- ***NERC SMWG would like to track oscillation information provided by ESAMS***
- ***The wide-area phase angle section is of interest, but in need of further development***
- ***EIDSN is a means for maintaining these capabilities***



Electric Power Group



ESAMS Next Steps

- Project final report in preparation
- Project team will complete SMWG oscillation templates
- Project outreach scheduled
 - NERC SMWG April 28/29
 - NERC RTOS May 3
- EIDSN Advisory Committee will make a decision regarding adoption this Summer/Fall



Electric Power Group



Thank You

Joe Eto
JHEto@lbl.gov



Electric Power Group

