







System Wide Event Analysis







SEL-311L

Event Type: BC T

Location: Transmission Line X

Global Id: 8b310b38815949ec84fb9bd5c7c286b5

Fault Location: 23.08

Trigger Time: 5/30/2013 3:58:50.624000 PM

Targets: 87

Fault Currents: IA=201 IB=2383 IC=2404

Acknowledged: False

File Type: Compressed ASCII (.CEV)



Events

1 SEL-311L 87L
1/2/2014 3:56:50.624000 PM

File: Sample 311L.cev
FID=SEL-311L-R102-V0-Z001001-D20010820
Event: BC T
Fault Location: 23.08
Frequency: 60 Hz Samples Rate: 16 Samples/Cycle
Targets: 87

Relay Settings Adjust Time



Custom Calculations

Displayed Quantities


| Co | Name | Mag | Angle |
|----|------------|-----|-------|
| 1 | 1:IA.Phase | 203 | -93.9 |
| 1 | 1:IB.Phase | 199 | 146 |
| 1 | 1:IC.Phase | 201 | 25.7 |

Chart Options

Show Magnitudes


Cursor Selection

Cursor 0



Analyze All Your Data in One Place

SYNCHROWAVE Central



SYNCHROWAVE Event 2015

