NERC NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

Welcome – NERC Update

Robert W. Cummings - NERC Director of System Analysis and Reliability Initiatives

NASPI Meeting

June 8, 2011

the reliability of the bulk power system

NASPI Funding



- Continuing near term support of NASPI as part of a plan to significantly reduce and potentially eliminate further funding by the end of 2013 as synchro-phasor technologies are commercialized
- NERC's 2012 NASPI budget amount increased by \$300k to reflect known and projected funding requirements
 - Including co-funding commitments in connection with the SEIGate Grant initiative
- Budget available at:

http://www.nerc.com/docs/bot/finance





3

- FNet being used to detect events and collect data in BAL-003 Frequency Response Standard Field Trial
 - Soon to add PMU fleet to FDRs
- Being incorporated into Modeling Validation Initiative
- Being commercialized in CAISO

Combination of tools used:

- Univ. of Tenn. Enhanced FNet System
 - High-speed sensors (10 samples/second)
 - Detects frequency excursions and estimates gen or load lost
 - Triangulates to estimate location of disturbance
 - Records data & calculates key frequency response factors
- CERTS Resource Adequacy (RA)Tool
 - Smart Alarm System
 - Based on 1-minute average frequency ICCP readings
 - Indicates frequency deviations and alarms beyond trigger levels
 - Provides BA-level variances in ACE

CERTS Frequency Monitoring and Analysis (FMA) Tool

After-the-fact analysis of detected and recorded data

FNet Sample Detection Output Trace of All Eastern Interconnection FDRs

59.70

8

19:37

19:37:31.1


19:37:36.

9:37:41.1

19:37:46.1



5



38:06.1-

38:11.1

38:16.1

38:01.1-

37:51.1

37:56.1

Courtesy of Power Information Technology Laboratory, University of Tennessee

38:26.

UsMoKirksville781 UsVaBlacksburg785 UsFIFsu786 UsNjAtlanticcity804 PointA 60.0080Hz

PointB 59.9541Hz


PointC 59.9492Hz

Scheduled_Freq 60.0000

FNET

38:21.

FNet Sample Output5 Point Median Eastern Interconnection



Median_Freq Scheduled_Freq 60.0000 PointA 60.0080Hz PointB 59.9541Hz PointC 59.9492Hz

Estimated Resource Loss 1,360 MW Actual Resource Loss 1,178 MW Delta Frequency A to C – 58.8 mHz A to B – 53.9 mHz Interconnection Frequency Response A-C -2,003 MW/0.1 Hz

A-B -2,186 MW/0.1 Hz

NORTH AMERICAN ELECTRIC

6

RELIABILITY CORPORATION

Courtesy of Power Information Technology Laboratory, University of Tennessee

FNet Sample Detection Output Trace of All Eastern Interconnection



7



Courtesy of Power Information Technology Laboratory, University of Tennessee

NERC Operating & Planning Committees


Quarterly presentations to both Committees

CORPORATION

8

Keen interest

Example of Withdrawal




AMERICAN ELECTRIC

Sample Analysis



10





11



Questions?

