

BPA Events from NERC's Forced Oscillation Guideline

NASPI-NERC Technical Workshop
September 27th



Timeline of BPA tools


- Before May 2013
 - SCADA
 - Research-grade PMU network
 - Engineer Responded
- May 2013 – June 2016
 - SCADA
 - Testing phase of Oscillation Detection Monitor (ODM)
 - Engineer Responded
- After June 2016
 - ODM went operational
 - System Operator Responds

Forced Oscillation Guideline Event 1: Controller Oscillation at Pacific HVDC Intertie


January 26, 2008



Event 1 System Conditions




Event 1



- Cause:
 - Celilo converter station had low short circuit ratio conditions, causing issues on the PDCI controllers

Event 1




- Response:
 - SCE staff contacted BPA and communicated the erratic readings from the oscillation
- Solution:
 - PDCI power transfer was lowered.
 - Repair of Valve Group tap changer on Celilo converter
 - Big Eddy transformer CT ratio error was corrected

Forced Oscillation Guideline Event 3: Wind Power Plant High Frequency Oscillations

May 2011 – April 2014











Event 3



Event 3




- Cause:
 - Nature of oscillation suggested voltage controller issues



- Response:
 - BPA Engineer contacted Plant Owner

Event 3

- Solution:
 - In April 2014, manufacturer upgraded the controls to fix the oscillation problem




Forced Oscillation Guideline Event 5: Control Interactions between UEL and PSS


October 2015




Event 5



Event 5



Event 5



- Cause:
 - Under-Excitation Limiter (UEL) and PSS started interacting

- Solution:
 - Move the units out of the UEL area.
- Response:
 - Plant engineer re-tuned UEL gains and retested.

Questions

Special thanks to Jim Burns, Dan Goodrich, Dmitry Kosterev, Jeff Anderson, Kliff Hopson, and Nick Leitschuh