



Naming Conventions

- Develop and Adopt a naming convention as soon as possible
 - Avoid thinking it will easily be fixed later
- Leverage existing naming conventions
- Involve Engineers, Operators, and IT in the development of the naming convention
- While not technically either Data Archive or Networking issue using a naming convention can significantly improve data use
- PMU and Signal names require different organization for use inside a utility vs. use by an RC or ISO
- Original naming conventions were simple. Deployment was typically bus voltage and line current. Now other equipment is being monitored with PMUs e.g. SynCon, Reactors, etc.




Naming Conventions



Utility internal naming convention

RC or ISO naming convention



PMU

Signal

